



# SLAB THICKENED EDGE/FOOTING SIZES.

## GENERAL NOTES:

- 1) 6"x6" 10/10 W/M OR FIBERMESH ADDED CONCRETE.
- 2) 6 MIL VISQUEEN VAPOR BARRIER REQUIRED.
- 3) TERMITE TREATED SOIL WHEN NEXT TO LIVING SPACE.
- 4) COMPACTION TEST REQUIRED WHEN FILL EXCEEDS 18".  
95% MINIMUM COMPACTION REQUIRED.
- 5) MINIMUM DEPTH FOR FOOTINGS WITH WOOD SIDING 18" DEEP.
- 6) MINIMUM DEPTH FOR FOOTINGS CONCRETE/STUCCO 16" DEEP.



## SLAB THICKENED EDGE SIZES.



## SLAB FOOTING SIZES.

